



# Bulk Asbestos Analysis by Transmission Electron Microscopy

NY ELAP : 198.4

**Customer:** Le Groupe Gesfor Poirier Pinchin  
6705 rue Jean Talon East St Office 211  
Montreal, QC H1S 1N2

**Attn:** Vincent Soulière

**Lab Order ID:** 10042586

**Project:** 1713003 037

**Analysis:** TOF  
**Date Received:** 02/02/2024  
**Date Reported:** 02/12/2024

Sample ID <i>Lab Sample ID</i>	Description <i>Lab Notes</i>	Organic ( Wt % )	Acid Soluble ( Wt. % )	Asbestos ( Wt % )		LCL-UCL ( Wt. % )
037-1e-tvc-01 <i>10042586_0016</i>	1 étage local 225, tuile vinyle beige lignée gris 12x12	22%	57%	0.21%	Chrysotile	0.19 - 0.23%
037-1e-tvc-02 <i>10042586_0017</i>	1etage corridor tuiles à plancher, tuile vinyle gris style armée 12x12	16%	82%	None Detected		
037-1e-tvc-03 <i>10042586_0018</i>	1etage local214 tuile à plancher, tuile vinyle beige brun 12x12	30.0%	59%	None Detected		
037-1e-tvc-04 <i>10042586_0019</i>	1etage local209 tuile a plancher, tuile vinyle blanc spotté gris 12x12	16%	84%	0.00058%	Chrysotile	0.00052 - 0.00064%
037-rdc-tvc-01 <i>10042586_0020</i>	Rdc corridor tuile à plancher, tuile vinyle gris 12x12	32%	54%	0.13%	Chrysotile	0.12 - 0.15%
037-rdc-tvc-02 <i>10042586_0021</i>	Rdc corridor tuile à plancher, tuile vinyle gris blanc 12x12	27%	73%	None Detected		
037-rdc-tvc-03 <i>10042586_0022</i>	Rdc passage 114 tuile à plancher, tuile vinyle gris crème 12x12	28%	68%	None Detected		
037-rdc-tvc-04 <i>10042586_0023</i>	Rdc local 102 tuile a plancher, tuile vinyle bleu 12x12	18%	79%	None Detected		

Disclaimer: This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. government.

Daniel Schwartz (11)

Analyst

Approved Signatory

Scientific Analytical Institute, Inc. 4604 Dundas Dr. Greensboro, NC 27407 (336) 292-3888



# Bulk Asbestos Analysis by Transmission Electron Microscopy

NY ELAP : 198.4

**Customer:** Le Groupe Gesfor Poirier Pinchin  
6705 rue Jean Talon East St Office 211  
Montreal, QC H1S 1N2

**Attn:** Vincent Soulière

**Lab Order ID:** 10042586

**Project:** 1713003 037

**Analysis:** TOF  
**Date Received:** 02/02/2024  
**Date Reported:** 02/12/2024

Sample ID	Description	Organic ( Wt % )	Acid Soluble ( Wt. % )	Asbestos ( Wt % )		LCL-UCL ( Wt. % )
Lab Sample ID	Lab Notes					
037-rdc-tvc-05	Rdc local 102 tuile a plancher, tuile vinyle bleu vert 12x12	30. %	44%	0.26%	Chrysotile	0.23 - 0.28%
10042586_0024						
037-rdc-tvc-06	Rdc local 103 tuile à plancher, tuile vinyle blanc et gris 12x12	29%	57%	0.13%	Chrysotile	0.12 - 0.15%
10042586_0025						
037-rdc-tvc-07	Rdc local 104 tuile a plancher, tuile vinyle rougeatre lignée gris fon	28%	48%	0.24%	Chrysotile	0.22 - 0.27%
10042586_0026						

Disclaimer: This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. This report may not be used by the client to claim product endorsement by NVLAP or any other agency of the U.S. government.

Daniel Schwartz (11)

Analyst

Approved Signatory

10042596

Version 2014-02-04

**Client:** Le Groupe Gesfor Poirier, Pinchin inc.  
**Contact:** Vincent Soulière  
**Address:** 6419, rue Jean-Talon Est  
 Montréal (Québec) H1S 3E7  
**Phone:** 514-251-1313  
**Fax:** 514-251-1818  
**Email:** vsouliere@gesfor.com  
 info@gesfor.com  
**Project:** 1713003  
**Client Notes:** Stop Positive First Layer  
 Analyze Asbestos Samples to 0.1%  
**P.O. #:** 1713003  
**Date Submitted:**  
**Analysis:** PLM IRSST 244-3/EPA 600  
**TurnAroundTime:** 10 days

**\*Instructions:**  
 Use Column "B" for your contact info

To See an Example Click the  
 bottom Example Tab.

Enter samples between "<<" and ">>"  
 Begin Samples with a "<<" above the first sample  
 and end with a ">>" below the last sample.  
 Only Enter your data on the first sheet "Sheet1"

Note: Data 1 and Data 2 are optional  
 fields that do not show up on the official  
 report, however they will be included  
 in the electronic data returned to you  
 to facilitate your reintegration of the report data.

Scientific Analytical Institute



4604 Dundas Dr.  
 Greensboro, NC 27407  
 Phone: 336.292.3888  
 Fax: 336.292.3313  
 Email: lab@sailab.com

Sample Number	Data 1 (Lab use only)	Sample Description	Data 2 (Lab use only)
---------------	-----------------------	--------------------	-----------------------

<<			
037-e1-cal-01		Tuyau-local 201-1, Calorifuge	
037-e1-cal-02		Tuyau-local 201-1, Calorifuge	
037-e1-cal-03		Local-201-1, Calorifuge	
037-e1-cal-04		Local-201-1, Calorifuge	
037-rdc-cre-04		Mur intérieur local 107, Crépis/plâtre	
037-rdc-cre-05		Plafond intérieur local-102, Crépis/plâtre	
037-rdc-cre-06		Plafond intérieur local-102, Crépis/plâtre	
037-1e-cre-01		Plafond intérieur local-225, Crépis/plâtre	
037-1e-cre-02		Mur intérieur local-225, Crépis/plâtre	
037-1e-cre-03		Plafond intérieur local-201, Crépis/plâtre	
037-1e-flo-01		Plafond intérieur local-201-1, Flocage	
037-e1-aco-01		Plafond-local 214, Tuile acoustique	
037-e1-aco-02		Plafond-local 214, Tuile acoustique	
037-rdc-aco-03		Plafond-couloir-rdc, Tuile acoustique	
037-rdc-aco-04		Plafond-couloir-rdx, Tuile acoustique	
037-1e-tvc-01		1 étage local 225, tuile vinyle beige lignée gris 12x12	
037-1e-tvc-02		1etage corridor tuiles à plancher, tuile vinyle gris style armée 12x12	
037-1e-tvc-03		1etage local214 tuile à plancher, tuile vinyle beige brun 12x12	
037-1e-tvc-04		1etage local209 tuile à plancher, tuile vinyle blanc spotté gris 12x12	
037-rdc-tvc-01		Rdc corridor tuile à plancher, tuile vinyle gris 12x12	
037-rdc-tvc-02		Rdc corridor tuile à plancher, tuile vinyle gris blanc 12x12	
037-rdc-tvc-03		Rdc passage 114 tuile à plancher, tuile vinyle gris crème 12x12	
037-rdc-tvc-04		Rdc local 102 tuile a plancher, tuile vinyle bleu 12x12	
037-rdc-tvc-05		Rdc local 102 tuile a plancher, tuile vinyle bleu vert 12x12	
037-rdc-tvc-06		Rdc local 103 tuile à plancher, tuile vinyle blanc et gris 12x12	
037-rdc-tvc-07		Rdc local 104 tuile a plancher, tuile vinyle rougeatre lignée gris forcé 12x12	
>>			

Accepted   
 Rejected

*Handwritten signature and date:*  
 2/1/14